



BOSCH

Certificate

We, Bosch Termoteknik AB, declare under own responsibility, that the model below are in conformity with the requirements of the specific standards/norms.

Buderus Logatherm: WPLS6.2 RE (RB/RT/RTS), WPLS8.2 RE (RB/RT/RTS), WPLS11.2 RE (RB/RT/RTS), WPLS13.2 RE (RB/RT/RTS)

Standards/norms:

- EN 14511

COP (Coefficient of Performance) and heating power values according to norm EN 14511 (A2/W35)

Model	COP value (A2/W35)*	Heating power (A2/W35) 100% compressor speed [kW]
Logatherm WPL6.2 RE (RB/RT/RTS)	3,50	8,4
Logatherm WPL8.2 RE (RB/RT/RTS)	3,50	9,2
Logatherm WPL11.2 RE (RB/RT/RTS)	3,60	13,1
Logatherm WPL13.2 RE (RB/RT/RTS)	3,55	14,2

* (COP at nominal heating power A2/W35, 60% compressor speed)

The product is manufactured under a production control system, which guarantees conformity between the manufactures products and technical data. Installation, connection, maintenance and usage should take place in accordance with the product's instructions and design, which described in the manufacturer's technical documentation as well as according to practice.

In accordance with the EC declaration of conformity, the product must not be modified without the manufacturer's permission. If this occurs, this documented EC declaration ceases to apply and the product's owner is considered to be the manufacturer and must verify and draw up an addendum to the EC declaration and file technical data for the inspection authority.

Tranas, 2017-08-21

Dr.rer.nat Thomas Finke
Managing Director

Achim Wiedemer
Head of Engineering Quality