

EU type examination certificate


EU-Baumusterprüfbescheinigung

CE-0085CS0332

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Distributor <i>Vertreiber</i>	Bosch Thermotechnik GmbH Sophienstraße 30-32, D-35576 Wetzlar
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Gas wall hanging condensing boiler with integrated heat exchanger for domestic hot water (DHW)
Model <i>Modell</i>	Buderus Logamax Plus GB022(i)...
Countries of Destination <i>Bestimmungsländer</i>	MD, PL, RO, TR
Test Reports <i>Prüfberichte</i>	supplement test: B 18/08/2767 EU from 30.08.2018 (DBI)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.09.2017) DIN EN 13203-1 (01.12.2015)

Date of Expiry / File No. 24.07.2028 / 18-0671-GEA
Ablaufdatum / AZ

11.09.2018 Rie B-1/2 i. 17. 
Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Elektrical Data
Elektrische Daten

230 V AC, 50 Hz

Appliance Categories <i>Geräte Kategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
II2ELwLs3B/P	20,20,13, 37 mbar	PL	
II2H3B/P	20, 30 mbar	RO, TR	
II2H3P	20, 37 mbar	RO, TR	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
GB022-24 K H	nominal heat output: 4,8...24,0 kW heat input (Hi): 4,9...24,5 (DHW: ...25,5) kW	
GB022-24 K H	nominal heat output: 4,8...20,0 kW nominal heat input (Hi): 4,9...20,4 (DHW: ...25,5) kW	
GB022i-24 K H	nominal heat output: 4,8...24,0 kW heat input (Hi): 4,9...24,5 (DHW: ...26,5) kW	

Hints of Utilization /Remarks
Verwendungshinweise / Bemerkungen

flue types: B23, B23P, B33, C13(x), C33(x), C43(x), C53(x), C63(x), C83(x), C93(x) according installation manual 6720886266

Additional proved countries of destination, appliance categories and supply pressures:

MD: II2H3B/P and II2H3P (20, 30 mbar)

In the NON-EU countries the CE-marking will be accepted as conformity approval if the Gas Appliance Regulation EU/2016/426 is transferred into national law by this countries.