


# CERTIFICATE

<b>Certificate holder</b>	<b>Bosch Thermotechnik GmbH</b> <b>Sophienstr. 30-32</b> <b>35576 Wetzlar</b> <b>GERMANY</b>
<b>Production facility</b>	Wettringen
<b>Product</b>	Solar collectors
<b>Type, Model</b>	Buderus SKT 1.0-s
<b>Testing basis</b>	DIN EN 12975-1:2011-01 DIN EN 12975-2:2006-06 Specific CEN Keymark Scheme Rules for Solar Thermal Products Version 30 (2017-04)

**Mark of conformity**

**Registration No.** 011-7S2081 F

**Valid until** 2023-06-30

**Nutzungsrecht** This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.

See annex for further information.

# ANNEX

Page 1 of 1

**Certificate**

011-7S2081 F dated 2018-06-13

**Technical Data**

See data sheet, part of the test report of 2013-06-03

**Note(s):**

- The freeze resistance test according to DIN EN 12975-2, clause 5.8 was not necessary. According to the manufacturer's declaration, the certified solar collectors may be used in frost exposed areas only in combination with appropriate frost protection mixtures or with appropriate frost protection controller.

**Testing laboratory/  
Inspection body**

TÜV Rheinland Energy GmbH  
51101 Köln  
GERMANY

**Test report(s)**

21221193\_EN\_Bosch dated 2013-06-03

